

SERVICE INFORMATION LETTER

COMPONENT MAINTENANCE RECOMMENDATIONS

Date: December 2, 2014

Subject: Scheduled Maintenance on Woodward Turbomachinery Auxiliary Components

The following recommendations regarding Woodward designed and manufactured auxiliary components have been developed to properly ensure the reliability, availability, and “safety of operation” expectations established for turbine engines. These recommendations include Woodward gas valves, actuators and mechanical controls. While there are electronic control systems designed to monitor and diagnose the operational performance of these components, control monitoring cannot replace normal preventative maintenance practices. It is important to follow these recommendations in order to avoid unnecessary and unscheduled shutdowns.

A detailed analysis has compared repair records of returned units, field data and design criteria to determine the following recommendations. An overhaul of the component should be completed on or before the unit reaches the recommended range of “Operating Hours” not to exceed 6 years in service. Recommendations are appropriately aligned with the standard OEM turbine maintenance schedules which are based on “normal” operating conditions, environment, fuel quality, and past maintenance history. Installations that do not meet “normal” operating conditions may require customized maintenance cycles to maximize reliability, performance and asset life. Contact your local Woodward representative for a detailed evaluation of your site conditions to determine the right maintenance cycles for your installation.

Woodward’s overhaul services will return the unit to “like new” condition ready for another full operating cycle to your next planned maintenance outage. Upon reaching the recommended maintenance cycle of the auxiliary component, please contact either the sites turbine OEM service representative, local Woodward Distributor or Woodward Authorized Independent Service Facility to facilitate services. A directory of your local Woodward authorized distributor or service facility can be found on the Woodward website at www.woodward.com/support/directory.cfm.

Eric Frieauf
Aftermarket Manager
Woodward Turbine Systems

Woodward Product Maintenance Recommendations

Revision 4 Date: December 2, 2014

Product Name	Maintenance Recommendation	
	Operating Hours*	Years in Service
AERO DERIVATIVE:		
Hydraulic Control Unit	50,000 Hours	6 years
Variable Geometry Hydromechanical Control	50,000 Hours	6 years
Variable Geometry Electromechanical Control	50,000 Hours	6 years
Variable Stator Vane Actuators	50,000 Hours	6 years
1907 Small Liquid Valves	25,000 Hours	3 years
1907 Large Liquid Valves	50,000 Hours	6 years
Liquid Shutoff Valves	50,000 Hours	6 years
LQ25 & LQ25T Liquid Metering Valves	50,000 Hours	6 years
1907 Small Gas Valves	25,000 Hours	3 years
3103/3171 Gas Valve with Hydraulic Actuator	50,000 Hours	6 years
3103/3171 Gas Valve with Electric Actuator	50,000 Hours	6 years
Gas Shutoff Valve	50,000 Hours	6 years
GS3/GS10 Gas Metering Valve	25,000 Hours	6 years
GS6/GS16 Gas Metering Valve	50,000 Hours	6 years
3151 Water Metering Valve	50,000 Hours**	6 years**
CIT/CDP Sensor	50,000 Hours	6 years
2057 Pump	50,000 Hours	6 years
Electric Gas Metering Valve (EGMV) on LMS100	50,000 Hours***	6 years***
Electric Water Metering Valve (EWMV) on LMS100	50,000 Hours***	6 years***
Electric Liquid Metering Valve (EMLV) on LMS100	50,000 Hours***	6 years***
Variable Bleed Vane (VBV) on LMS100	50,000 Hours	6 Years

HEAVY FRAME:		
Globe Gas Fuel Control Valve (Hydraulic and Electric Actuated)	50,000 Hours***	6 years***
SonicFlo Gas Fuel Control Valve (Hydraulic and Electric Actuated)	50,000 Hours***	6 years***
Rotary Fuel Control Valve (Hydraulic, Electric, Pneumatic Actuated)	50,000 Hours***	6 years***
3-Way Liquid Fuel Control Valve (Hydraulic Actuated)	50,000 Hours	6 years
2 - Way Liquid Fuel Valve (Hydraulic and Electric Actuated)	50,000 Hours***	6 years***
2 – Way Water Metering Valve (Hydraulic and Electric Actuated)	50,000 Hours***	6 years***
Inlet Guide Vane (IGV) Actuator	50,000 Hours	6 years
Variable Guide Vane (VGV)	50,000 Hours	6 years

*Woodward considers its valves and actuators as key components in the overall fuel efficiency, emissions control and safety of the gas turbine. Therefore, we recommend that our products be overhauled at the same regular intervals that the gas turbine “Hot Section” or “Major Inspections” occur. Please consult the Gas Turbine OEM guidelines for recommended service intervals for your turbine.

** Per the product manual guidance complete sleeve indexing maintenance procedure as recommended.
Manual 40120 “3151A Water Valve/TM-40LP Actuator Assembly for Gas Turbine Water Injection System”
Manual 40181 “3151A Water Valve EML100 Actuator Assembly for Gas Turbine Water Injection System”

*** Per the product manual guidance for electric actuation, complete re-greasing maintenance procedure at recommended intervals.
Contact your local Woodward distributor for re-greasing kits.